

## January 2023 Utility Report

During the month of January the Town of Outlook Water plant produced a total of 5'898'900 Imperial Gallons of water. The high/Low chlorine Total range was 1.16-2.00mg/L, and the chlorine free range was 1.01-1.69mg/L. The turbidity range off the filters was 0.063-0.096 NTU. The truck fill sold a total of 223.9 cubic meters of water.

On January 19<sup>th</sup> we had a Water plant/Distribution system from Water Security Agency, this was our first inspection with our new temporary EPO Dave Broughton. Inspection was successful, we maintained full compliance since last inspection.

On January 20<sup>th</sup> we replaced a failed pump and discharge hose at the East Sewage Lift Station, the new lift pump has been operating efficiently since replacement. The "old" sewage lift pump has been sent for repairs, and is now available for pickup to remain in our stock for emergency use.

We experienced furnace issues on our East filter furnace, as well as our basement furnace. The East filter furnace had a faulty blower motor replaced, and the basement furnace has some maintenance done on it. East furnace is working as intended, but our basement furnace may need some more work, a plumber will be coming to inspect and provide an appropriate follow up.

We have renovated our Water plant stock shelves to accommodate some WTP upgrades slated to take place this year, pictures provided below.

