

July 2023 Utility Report

During the month of July the Town of Outlook Water plant produced a total of 11'426'400 Imperial Gallons of water (11'452'800 Imp. G. previous month). The high/Low chlorine Total range was 1.47-2.10mg/L, and the chlorine free range was 1.28-1.87mg/L. The turbidity range off the filters was 0.061-0.131NTU. The truck fill sold a total of 696.2 Cubic meters of water (1601.2 Cu.M previous month).

We experienced issues with our CL17 chlorine analyzer at the WTP and it was out of commission, but the instrument has had the entire tubing harness replaced and system recalibrated. The unit has been operating as normal since.

On July 31st we had our clear well run dry again, causing the distribution system to lose pressure for about 5 minutes, this is a known and ongoing issue, and we followed our EPO's recommendations following re-pressurization. We continue to do preventative maintenance on these problem valves and monitor, and they are included in WTP upgrades coming in the near future.

The rate at the truck fill increased in early July.

River levels have still been maintaining sufficient levels so far this season.